
ENERNOC
Today's DR Performance
Don
avier University - Cincinnati - OH 0680371301
EnerNOC DemandSMART - PJM Emergency Load Response
Aug 10, 2017
2:15pm - 4:00pm
The dispatch is now over
Average Performance met Target
Demand (kW)
5K
4K
3K
2K
1K
0
1:00pm EDT
2:00pm EDT
3:00pm EDT
4:00pm EDT
5:00pm EDT
3:50pm EDT
Baseline 4,846 kW
Demand 1,633 kW
Target 1,929 kW or less
Performance 3,213 kW (110.15%)