

Xavier Armory

Fire Prevention Plan

for

Xavier Armory

3908 Winding Way

Xavier University
October 12, 2006

Table of Contents

Fire Prevention Plan

Introduction	3
Responsibilities	3
Major Workplace Fire Hazards	3
Methods of Handling and Storage	4
Potential Ignition Sources	4
Housekeeping	4
Training	5

Fire Prevention Plan

1. Introduction

This Fire Prevention Plan has been developed to identify workplace fire hazards and their control procedures. It also addresses the type of fire protection equipment or systems available in the building, the responsibilities of employees to reduce and respond to fire hazards, and the names of those personnel responsible for maintenance of fire protection equipment. This Fire Prevention Plan (FPP) includes the Armory location at 3908 Winding Way on the campus of Xavier University for *Armory* employees. This plan is designed to comply with the Occupational Safety and Health Administration (OSHA) Standard 29 CFR 1910.38

2. Responsibilities

2.1 *Portable Fire Extinguishers*

The Armory of Xavier University is equipped with type ABC portable fire extinguishers. A monthly inspection is conducted by Physical Plant personnel to ensure that extinguishers are charged, accessible and in overall good condition. An annual inspection is conducted by a contractor, who is responsible for recharging the extinguishers and ensuring that mounts are in good condition. Following is the name and phone number of the contractor performing this duty:

<u>Name</u>	<u>Phone Number</u>
Cintas Fire Protection	751-8384

2.2 *Fire Suppression Systems*

There are no fire suppression systems installed in the Armory at the present time.

3. Major Workplace Fire Hazards

The following is a list of potential workplace fire hazards, which could be encountered in the Armory:

- Solvents and other flammable or combustible chemicals used in the building. This includes, but is not limited to cleaning solvents, paint products, and vehicle maintenance products. The Material Safety Data Sheet (MSDS) should be

referenced to determine which materials fall into this classification.

- Fuels used for lawn mowers, vehicles, snow blowers, etc.
- Waste paper, cardboard and other combustible waste.
- While not actually a fire hazard, it is important for the fire department to note that as many as 5,000 rounds of special .22 caliber ammunition with plastic bullets may be stored in the ROTC supply room in the Armory basement. It is stored in a vault of cinder block construction, and the ammunition is in a metal cabinet inside the vault. The ammunition is stored at Xavier for use at other locations.

4. Methods of Handling and Storage

Paper products (e.g., waste paper, cardboard) are removed and disposed of on a regular basis so that large amounts are not accumulated in the Armory.

Fuels and maintenance products are stored away from open flames or in fire resistant cabinets.

5. Potential Ignition Sources and Control

Potential ignition sources include matches, lighters, ignited cigarettes, flames and sparks generated from welding or cutting operations. Some flammable materials may ignite from prolonged exposure to heat. Sources of heat include radiators, space heaters, water heaters, boilers and the sun.

Potential ignition source control is conducted through various means. These include but are not limited to the following; a) prohibition of the use of matches, lighters, and smoking products in University buildings; b) prohibition of welding or cutting in areas containing flammable or combustible materials; c) the proper storage and handling of rags containing flammable or combustible materials; d) proper storage of fuel and chemical containers.

6. Housekeeping

The following individuals are designated as responsible for the control of fuel source hazards (i.e., controlling accumulations of flammable and combustible materials so that they do not contribute to a fire emergency). These employees and their material of concern are as follows:

<u>Name</u>	<u>Location</u>	<u>Material of Concern</u>
Building Coordinator	St. Barbara's Hall	General Building Cleanliness

Associate Director of Building Services	Alumni Center	Waste paper, cardboard and other combustible waste
Logistic Technician	Armory	ROTC .22 caliber ammunition

Housekeeping procedures to control accumulations of flammable and combustible waste materials are described below:

- Large amounts of flammable products are stored in fire resistant storage cabinets that are located away from open flames or high heat sources. Smaller amounts of flammable and combustible products are stored away from open flames and high heat sources.
- Physical Plant personnel are responsible for disposal of materials that are potentially flammable or combustible. These include chemicals, waste paper, cardboard, etc. Armory personnel also are responsible for ensuring that materials that are placed in waste containers are away from potential ignition sources.

7. Training

Training will be provided to all Armory personnel. This Fire Prevention Plan will be reviewed with employees at the following times:

- When the plan is developed
- Whenever the employee's responsibility changes
- Whenever the plan is changed